



# ONE-LINE DIAGRAM

NO SCALE

PER NEC 250.52(A)(3) CONCRETE-ENCASED ELECTRODES WHEN A MINIMUM 4 AWG REBAR IS USED, THE CONCRETE-ENCASED ELECTRODE SHALL BE CONNECTED PER NEC 250.70 TO A MINIMUM 4 AWG COPPER CONDUCTOR (NEC 250.55(B)) BACK TO THE MAIN DISTRIBUTION PANEL COPPER GROUND BUSS

